

Message

From: Stansfield, Michael [Michael.Stansfield@dnr.mo.gov]
Sent: 8/17/2015 9:39:48 PM
To: Hess, Alana [Alana.Hess@dnr.mo.gov]
Subject: FW: AEI New Madrid Power Plant - CAM Plan Testing

Alana,

I am inclined to grant this request on the basis that we will get the test results for both units sometime next summer. Additionally, I would expect to see more consistent results between the two units if they are tested at the same time. Without meaning for you to spend time digging into the situation, do you know of any reason why AEI shouldn't be allowed to do this testing next summer?

Thank you,
Michael J. Stansfield, P.E.
Operating Permit Unit Chief
Missouri Department of Natural Resources
Air Pollution Control Program
PO Box 176
Jefferson City, MO 65102-0176
voice: (573) 751-4817

Promoting, Protecting and Enjoying our Natural Resources. Learn more at dnr.mo.gov.

From: Peterson, Sharon [mailto:speterson@aeci.org]
Sent: Friday, August 07, 2015 12:20 PM
To: Stansfield, Michael
Subject: AEI New Madrid Power Plant - CAM Plan Testing

Hello Mike,

I have a question in regard to scheduling of PM testing to validate and reset the curve (PM vs Percent Opacity) that was established in the New Madrid CAM Plan. With the recent Title V Renewal Application that was submitted for New Madrid, AEI informed DNR in the cover letter that maintenance was performed last spring on the ESP on Unit 2 in Spring 2015. Unit 1 ESP maintenance is planned for Spring 2016. I reviewed our CAM Plan and 40 CFR Part 64 and did not see a defined time period at which the testing should be conducted. Will it be acceptable for AEI to wait until the completion of Unit 1 and conduct PM testing on both units during the same stack testing mobilization in the Summer of 2016? Prior to the testing AEI will provide a testing protocol to DNR. Additionally AEI will provide the revised CAM plan following the testing. Can you assist us in providing some timeframes and deadlines so that we can schedule and budget the testing accordingly?

Thanks,

Sharon Peterson

Sr. Environmental Analyst

Associated Electric Cooperative, Inc.
2814 S. Golden Ave.
Springfield, MO 65801
Office: 417.885.9321
Cell: 573.433.1358